

TEST REPORT

No. : GZMR220300569901

Date : Mar 21, 2022

Page: 1 of 3



CUSTOMER NAME: EVAGROUP AUSTRALIA PTY LTD
ADDRESS: BLDG 2F 57 LOFTUS RD, YENNORA NSW 2161, AUSTRALIA

Sample Name : ECOSET MS FLOORING ADHESIVE

Above information and sample(s) was/were submitted and confirmed by the client. SGS, however, assumes no responsibility to verify the accuracy, adequacy and completeness of the sample information provided by client.

SGS Ref. No. : CQ10007545
Date of Receipt : Mar 10, 2022
Testing Start Date : Mar 10, 2022
Testing End Date : Mar 21, 2022
Test result(s) : For further details, please refer to the following page(s)
(Unless otherwise stated the results shown in this test report refer only to the sample(s) tested)

Signed for
SGS-CSTC Standards Technical
Services Co., Ltd. Guangzhou Branch
Testing Center

Cathy Peng
Authorized signatory



TEST REPORT

No. : GZMR220300569901

Date : Mar 21, 2022

Page: 2 of 3

Summary of Results:


No.	Test Item	Test Method	Result	Conclusion
1	Water Vapor Transmission	ASTM E96/E96M-21 Procedure A	0.146g/(m ² ·h)	/

Note: Pass : Meet the requirements;
 Fail : Does not meet the requirements;
 / : Not Apply to the judgment.

Test Sample Description:

Report Sample No.	Lab Sample No.	Description
A	001	Sheet

Original Sample Photo:



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
 Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

TEST REPORT

No. : GZMR220300569901

Date : Mar 21, 2022

Page: 3 of 3

Test Item: Water Vapor Transmission

Test Method: ASTM E96/E96M-21 Procedure A

Test Condition:

Specimen thickness: 2.64mm

Transmission area: 0.003295m²

Test condition: (23±2)°C, (50±5)%RH


Lab Environmental Condition: (23±2)°C, (50±5)%RH

Test Result:

Test Item	Test Result
Water Vapor Transmission Rate	0.146g/(m ² ·h)

Note: Test specimens were cut from the sample.

Test Photo:



Equipment Information:

Equipment	Model	Equipment No.	Calibration date	Next Calibration date
Electron Balance	XPE404S	GZMR-PL-E004-07	2021-10-22	2022-10-21

***** End of report*****



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS-CSIC Guangzhou Branch Testing, Calibration & Reliability Laboratory

198 Kaszu Road, Solentech Park Guangzhou Economic & Technology Development District, Guangzhou, China 510663 t(86-20) 82155555 f(86-20) 82075188 www.sgsgroup.com.cn
中国·广州·经济技术开发区科学城科珠路198号 邮编:510663 t(86-20) 82155555 f(86-20) 82075188 e sgs.china@sgs.com